



**KERALA AGRICULTURAL UNIVERSITY**  
**KELAPPAJI COLLEGE OF AGRI ENGG & TECHNOLOGY**

Tavanur-679573, Malappuram (Dt), Kerala  
Email: deanengg@kau.in, kcaet@kau.in; Ph: 0494 2686214

No. B3- 2018/12

Dated: 07-11-19

**QUOTATION NOTICE**

Sealed competitive quotations are invited for extending LPG pipeline in the Microbiology Lab of this College.

**Description of Work :**

- Supply and Installation of Copper LPG Pipeline from a 2 cylinder LPG cylinder station to 5 burner points in the Microbiology lab. The approximate length of the gas pipeline from cylinder station to the last burner point is 13 meters. The main copper LPG pipe should be of 14 gauge thick with 3/8" inner diameter and 5/8" outer diameter. All fittings like elbows, T-joints clamps bends etc should be brass. Each gas cylinders should be provided with ISI standard regulator valve pressure gauge and 1 meter LPG hose. Each burner points should be provided with ISI standard Brass/Stainless steel gate valve and 1 meter LPG hose. The rate should cover the cost of copper LPG gas pipe, all fittings and installation charges inclusive of all taxes.

**Terms and Conditions**

1. The rate of copper LPG gas pipe, all fittings and installation charges should be quoted separately.
2. The rates quoted should be inclusive of all taxes and other charges if any and the items shall be delivered& installed at the point specified by the undersigned.
3. The quotations should reach this office before 2.30 pm on 16-11-19 and the quotation will be opened at 3.00 pm on the same day.
4. Late and defective quotations will not be accepted.
5. The envelope containing the quotation should be super scribed "Quotation for the Supply and Installation of Copper LPG Pipeline of as per order No. B3-2018/12" and addressed to the Dean (Ag. Engg), KCAET, Tavanur, Malappuram (Dt) Pin-679 573.
6. All rules related to Government quotations will be applicable in this case also.

Sd/-

**Velayudhan.K**  
**Administrative Officer i/c**  
**For Dean (Agr. Engg)**

To KAU Website, KCAET Website